

Town of Fortville
Utility Street Standards

SECTION 02558 - LOCATOR WIRE

PART 1 - GENERAL

1.1 SCOPE

Contractor shall furnish and install locator wire over the centerline of all buried non-metallic piping.

PART 2 - PRODUCTS

2.1 MATERIAL

Location wire shall be blue coated #10 solid copper

PART 3 - EXECUTION

3.1 INSTALLATION

- A. Locator Wire shall be installed over all buried non-metallic piping in accordance with the manufacturer's installation instructions. Wire shall be installed over the centerline of pipe unless otherwise noted on plans.

END OF SECTION 02558